

INSPECTION BODY ACCREDITATION PROGRAM (IBAP)

Scope of Accreditation

Accredited Legal Entity: Vision Integrity Engineering Ltd.

Contact Name: Adam Maclean

LOCATION A

Address: 1229 13th Ave SW

Calgary, Alberta

T3C 0T2

Telephone: 800 442-8721

Website: www.visionintegrity.ca

Email: adam.maclean@visionintegrity.ca

SCC File Number:	06026
Accreditation Standards:	ISO/IEC 17020:2012 – Conformity assessment Requirements for the operation of various types of bodies performing inspection
Additional Accreditation Requirements:	SCC Requirements and Guidance for the Inspection Body Accreditation Program 2022-05-27 (v6)
Accreditation Sub-Programs:	Field evaluation of electrical equipment
Initial Accreditation:	2018-02-22
Most Recent Accreditation:	2023-04-05
Accreditation Valid to:	2026-02-22

Additional Fixed Office Locations:

Refer to the legal entity location identified at the top of this listing. There are no additional locations included in this scope of accreditation:

Operation Type of Inspection Body:

ISO/IEC 17020, Conformity assessment — Requirements for the operation of various types of bodies performing inspection, Annex A Independence requirements for inspection bodies, Type A most closely resembles the operation type operated by this organization. The inspection body shall be independent of the parties involved. The inspection body and its personnel shall not





engage in any activities that may conflict with their independence of judgment and integrity in relation to their inspection activities. They shall not be engaged in the design, manufacture, supply, installation, purchase, ownership, use or maintenance of the items inspected. An inspection body shall not be a part of a legal entity that is engaged in design, manufacture, supply, installation, purchase, ownership, use or maintenance of the items inspected. The inspection body shall not be linked to a separate legal entity engaged in the design, manufacture, supply, installation, purchase, ownership, use or maintenance of the items inspected by the following: 1) common ownership, except where the owners have no ability to influence the outcome of an inspection; 2) common ownership appointees on the boards or equivalent of the organizations, except where these have functions that have no influence on the outcome of an inspection; 3) directly reporting to the same higher level of management, except where this cannot influence the outcome of an inspection; 4) contractual commitments, or other means that may have an ability to influence the outcome of an inspection.

Scope of Accreditation:

I: Electrical Equipment Program

Base program:	SPE-1000 Field Evaluation/Special Inspection	
Inspection Standards	SPE-1000: Model code for the field evaluation of electrical equipment Canadian Electrical Code	
Inspection Label	FIELD EVALUATION VISION INTEGRITY ENGINEERING LTD. This product is evaluated to the Model Code SPE-1000. Such evaluation does not constitute certification but is an accepted form of approval of electrical products by the authority having jurisdiction. SERVICE D'ÉVALUATION SUR PLACE VISION INTEGRITY ENGINEERING LTD. The label presented above is in accordance with CSA-SPE-1000 and is effective as of 2018-02-22.	
Locations:	A	
Scope of Accreditation	The performing of field evaluations/special inspections and the application of approval labels on electrical equipment and systems in accordance with all of the following: As identified in the scope of CSA SPE-1000 Model Code for the field evaluation/special inspection of electrical equipment, but excluding: a) wire and cable products; b) wiring devices; c) equipment for use in hazardous locations; d) medical electrical equipment and systems;	



- e) components* that will require further evaluation as part of a complete assembly, such as switches, relays, and timers;
- f) equipment connected to line voltage in excess of 46 kV;
- g) manlifts, elevators, climb assists and similar systems (other than their associated control panels); and
- h) any equipment that is not permitted to be field evaluated as directed by an AHJ (such as residential air-cleaning equipment that intentionally produces ozone).

*Field evaluation/special inspection only applies to equipment that is capable of being connected to the supply in accordance with the Canadian Electrical Code, Part I.

This document forms part of the Certificate of Accreditation issued by the Standards Council of Canada (SCC) to Vision Integrity Engineering Ltd. The original version is available in the Directory of Accredited Inspection Bodies on the SCC website at www.scc.ca.

Elias Rafoul Vice-President, Accreditation Services Publication on: 2024-02-22

