

INSPECTION BODY ACCREDITATION PROGRAM (IBAP)

Scope of Accreditation

Accredited Legal Entity: International Testing Laboratory Inc.

Contact Name: Aman Jathaul

LOCATION A

Address: Unit 105-12031 Horseshoe Way
Richmond, British Columbia
V7A 4V4

Telephone: 604 238 5060

Website: www.intertestlab.com

Email: aman.jathaul@intertestlab.com

SCC File Number:	06034
Accreditation Standards:	ISO/IEC 17020:2012 – Conformity assessment -- Requirements for the operation of various types of bodies performing inspection
Additional Accreditation Requirements:	SCC Requirements and Guidance – Inspection Body Accreditation Program, v6, 2022-05-27
Accreditation Sub-Program:	Field evaluation of electrical equipment
Initial Accreditation:	2021-01-07
Most Recent Accreditation:	2022-05-19
Accreditation Valid to:	2025-04-01

Additional Fixed Office Locations:

Refer to the legal entity location identified at the top of this listing. There are no additional locations included in this scope of accreditation:


Operation Type of Inspection Body:


ISO/IEC 17020, Conformity assessment — Requirements for the operation of various types of bodies performing inspection, Annex A Independence requirements for inspection bodies, Type A most closely resembles the operation type operated by this organization. The inspection body shall be independent of the parties involved. The inspection body and its personnel shall not engage in any activities that may conflict with their independence of judgment and integrity in

relation to their inspection activities. In particular, they shall not be engaged in the design, manufacture, supply, installation, purchase, ownership, use or maintenance of the items inspected. An inspection body shall not be a part of a legal entity that is engaged in design, manufacture, supply, installation, purchase, ownership, use or maintenance of the items inspected. The inspection body shall not be linked to a separate legal entity engaged in the design, manufacture, supply, installation, purchase, ownership, use or maintenance of the items inspected by the following: 1) common ownership, except where the owners have no ability to influence the outcome of an inspection; 2) common ownership appointees on the boards or equivalent of the organizations, except where these have functions that have no influence on the outcome of an inspection; 3) directly reporting to the same higher level of management, except where this cannot influence the outcome of an inspection; 4) contractual commitments, or other means that may have an ability to influence the outcome of an inspection.

Scope of Accreditation:

I: Electrical Equipment Program

Base program:	SPE-1000 Field Evaluation/Special Inspection
Inspection Standards	SPE-1000: Model code for the field evaluation of electrical equipment Canadian Electrical Code
Inspection Label	 <p>The label presented above is in accordance with CSA SPE-1000 and is effective as of July 15, 2022.</p> <p>Product inspected to CSA SPE-1000 between January 07, 2021 and July 14, 2022 was labelled in accordance with CSA SPE-1000 as represented by the label below</p>

	<p style="text-align: center;">Special Inspection Services / Services D'inspection Spéciaux</p> <div style="display: flex; justify-content: space-between;"> <div style="width: 20%;"> <p style="writing-mode: vertical-rl; transform: rotate(180deg);">XXXX-XXXX</p> </div> <div style="width: 30%; text-align: center;"> <p>SPE-1000</p>  <p>INIL</p> <p>www.intertestlab.com</p> </div> <div style="width: 40%;"> <p>This product is evaluated to the Model Code SPE-1000. Such evaluation does not constitute certification but is an accepted form of approval of electrical products by authority having jurisdiction.</p> <p>Ce produit est évalué selon le code modèle SPE-1000. Une telle évaluation ne constitue pas une certification mais est une forme acceptée d'approbation des produits électriques par l'autorité compétente.</p> </div> </div> <div style="display: flex; justify-content: space-between; margin-top: 10px;"> <p>Ph: 778-927-9696</p> <p>Email: info@intertestlab.com</p> </div>
<p>Locations:</p>	<p>A</p>
<p>Scope of Accreditation</p>	<p>The performing of field evaluations/special inspections and the application of approval labels on electrical equipment and systems in accordance with all of the following:</p> <p>As identified in the scope of CSA SPE-1000 Model Code for the field evaluation/special inspection of electrical equipment, but excluding</p> <ol style="list-style-type: none"> a) wire and cable products; b) wiring devices; c) equipment for use in hazardous locations; d) medical electrical equipment and systems; e) components* that will require further evaluation as part of a complete assembly, such as switches, relays, and timers; f) equipment connected to line voltage in excess of 46 kV; g) manlifts, elevators, climb assists and similar systems (other than their associated control panels); and h) any equipment that is not permitted to be field evaluated as directed by an AHJ (such as air-cleaning equipment that intentionally produces ozone). <p>*Field evaluation/special inspection only applies to equipment that is capable of being connected to the supply in accordance with the Canadian Electrical Code, Part I.</p>

Note:

This document forms part of the Certificate of Accreditation issued by the Standards Council of Canada (SCC) to International Testing Laboratory Inc. The original version is available in the Directory of Accredited Inspection Bodies on the SCC website at www.scc.ca.

Elias Rafoul
Vice-President, Accreditation Services
Publication on: 2024-12-09